

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 6606

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
FWP-A	Fire Water Pump Engine (6)	CO	0.85	0.04
		NO _x	4.88	0.24
		PM	0.34	0.02
		PM ₁₀	0.34	0.02
		PM _{2.5}	0.34	0.02
		SO ₂	0.01	<0.01
		VOC	0.10	0.01
FWP-B	Fire Water Pump Engine (6)	CO	0.85	0.04
		NO _x	4.88	0.24
		PM	0.34	0.02
		PM ₁₀	0.34	0.02
		PM _{2.5}	0.34	0.02
		SO ₂	0.01	<0.01
		VOC	0.10	0.01
TK-28082	Fire Water Pump Fuel Tank	VOC	0.03	0.01
TK-28083	Fire Water Pump Fuel Tank	VOC	0.03	0.01
MVCU1	Marine Vapor Combustion Unit No. 1	CO	5.40	--
		H ₂ S	0.06	--
		NO _x	4.14	--
		SO ₂	11.78	--
		PM	1.35	--
		PM ₁₀	1.35	--

EMISSION SOURCES – MAXIMUM ALLOWABLE EMISSION RATES

		PM _{2.5}	1.35	--
		VOC	3.10	--
MVCU2	Marine Vapor Combustion Unit No. 2	CO	5.40	--
		H ₂ S	0.06	--
		NO _x	4.14	--
		SO ₂	11.78	--
		PM	1.35	--
		PM ₁₀	1.35	--
		PM _{2.5}	1.35	--
		VOC	3.10	--
		MVCU3	Marine Vapor Combustion Unit No. 3	CO
H ₂ S	0.06			--
NO _x	4.14			--
SO ₂	11.78			--
PM	1.35			--
PM ₁₀	1.35			--
PM _{2.5}	1.35			--
VOC	3.10			--
MVCU1 / MVCU2 / MVCU3	Combined Annual Emission Limit for MVCUs	CO	--	34.01
		H ₂ S	--	0.2
		NO _x	--	26.08
		SO ₂	--	38.10
		PM	--	8.50
		PM ₁₀	--	8.50
		PM _{2.5}	--	8.50
		VOC	--	14.70
TK-28067	Tank No. 28067	H ₂ S	0.14	0.09
		VOC	21.09	9.20
TK-28068	Tank No. 28068	H ₂ S	0.12	0.07

EMISSION SOURCES – MAXIMUM ALLOWABLE EMISSION RATES

		VOC	18.53	7.66
TK-28069	Tank No. 28069	H ₂ S	0.07	0.04
		VOC	17.95	5.84
TK-28070R	TK-28070R	H ₂ S	0.02	0.01
		VOC	12.90	5.55
TK-28071	Tank No. 28071	H ₂ S	0.09	0.06
		VOC	14.42	6.00
TK-28072	Tank No. 28072	H ₂ S	0.13	0.09
		VOC	14.97	7.71
TK-28073	Tank No. 28073	H ₂ S	0.13	0.08
		VOC	14.91	7.53
TK-28074	Tank No. 28074	H ₂ S	0.14	0.09
		VOC	15.02	7.89
TK-28075	Tank No. 28075	H ₂ S	0.13	0.09
		VOC	14.97	7.83
TK-28076	Tank No. 28076	H ₂ S	0.14	0.09
		VOC	15.00	7.82
TK-28077	Tank No. 28077	H ₂ S	0.09	0.05
		VOC	20.32	6.76
TK-28080	Tank No. 28080	H ₂ S	0.13	0.09
		VOC	14.97	7.72
TK-28086	Tank No. 28086	H ₂ S	0.13	0.09
		VOC	14.26	7.56
TANKGRP1	Annual Tank Emission Cap for Tanks 28063, 28064, 28067-28077, 28080, 28086 (7)	VOC	--	67.74
TK-28087	Tank 28087	H ₂ S	0.03	--
		VOC	12.84	--
TK-28088	Tank 28088	H ₂ S	0.03	--
		VOC	12.84	--

EMISSION SOURCES – MAXIMUM ALLOWABLE EMISSION RATES

TK-28089	Tank 28089	H ₂ S	0.03	--
		VOC	12.84	--
TK-28090	Tank 28090	H ₂ S	0.03	-
		VOC	12.84	-
TANKGRP2	Annual Tank Emission Cap for Tanks 28087, 28088, 28089, 28090, 28091, 28092 (8)	H ₂ S	-	0.03
		VOC	-	9.02
FUG-1	Terminal Fugitives (5)	H ₂ S	0.10	0.09
		VOC	1.27	5.56
DOCK	Ship and Barge Loading Dock	VOC	6.38	8.58
		H ₂ S	0.02	0.02

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) CO - carbon monoxide
H₂S - hydrogen sulfide
NO_x - total oxides of nitrogen
PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
SO₂ - sulfur dioxide
VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) Planned operation of the two fire water pump engines (EPNs FWP-A and FWP-B) is limited to 100 hours per engine per rolling twelve months and a combined four hours in any 24-hr period.
- (7) Tank numbers TK-280 (63, 64, 67 through 77, 80 and 86) are each subject to their individually listed hourly and annual VOC emission rates. In addition, the total annual VOC emission rate from these identified floating roof storage tanks shall not exceed the listed EPN TANKGRP1 emission limits.
- (8) Tank numbers TK-280 (87 through 92) are subject to its individually listed hourly and annual H₂S and VOC emission rate. The total annual H₂S and VOC emission rates from these identified floating roof storage tanks shall not exceed the listed EPN TANKGRP2 emission limits.

Date: Draft